

## Amber Virkler

---

**From:** Shanel Lindsay <shanel.lindsay@gmail.com>  
**Sent:** Tuesday, April 18, 2023 12:04 PM  
**To:** Amber Virkler  
**Cc:** Miriam Magid; nicole@m4mmunited.org  
**Subject:** Re: The Billow and proposed changes to NCCR  
**Attachments:** Draft amendment to NCCR 15.055.pdf

**WARNING** - This email originated from outside the State of Nevada. Exercise caution when opening attachments or clicking links, especially from unknown senders.

Hi Amber,

Please see attached the proposed draft language to NCCR 15.055. Thank you!

Add to NCCR 15.055:

“9. As an alternative to 15.055.1-4, a consumption lounge may use an odor containment and elimination device that achieves or exceeds the air quality of the systems outlined in 15.055.1-4 and includes:

- a chamber that contains the combustion material and associated smoke and achieves at least 30 complete air changes per hour
- a release point configured for inhalation of the smoke air by a user
- A pressurized pathway that suctions the smoke exhaled by the user
- A HEPA filter that filters the smoke from the chamber and smoke exhaled by the user into the pressuized pathway.

Lounges utilizing this alternative shall submit a yearly report demonstrating that the lounge remains at or below average and peak PPM concentrations for systems outlined in 15.055.1-4.”